


(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail : erda@erda.org

Web : http://www.erda.org

TEST REPORT



NAME & ADDRESS OF CUSTOMER	REPORT NO.: RP-1516- DATE : 29.03.201	
Tibrewala Electronics Ltd.	CUSTOMER REF.NO.	DATE
Bombay Highway, Balanagar, Hyderabad-500037	TEL/ERDA/2015-2016	28.01.2016
Andhra Pradesh, India.	DATE OF SAMPLE RECEIPT	DATE OF TESTING
	28.01.2016	08.02.2016 to 18.03.2016
SAMPLE DESCRIPTION	SAMPLE IDENTIFICAT	TION
AC MOTOR CAPACITORS Rated Capacitance: 35 MFD ± 5% Rated voltage: 440V AC Rated frequency: 50/60 Hz Type of dielectric: MPP Ref. to self-healing: SH Climate category: -25°C to +85°C	ERDA Sample code Nos ERDA-00125355 to ERDA Marking no.: 1 to 31 Manufactured by: Tibr Brand name: TIBCON C	-00125385 (31 Nos.) rewala Electronics Ltd.
Reference to IS : IS 2993:1998 Class of Safety Protection: P2 10000 AFC PROTECTED	ENCLOSURE : Photographs of test samp no. and name plate, as p	
TEST DETAILS	TEST SPECIFICATION	

TEST RESULTS: As per sheets 3 of 11 to 10 of 11.

REMARKS: 1) The capacitor **conforms** to the requirements of test specification for test no. 1 to 5 & 7 to 8 as per sheet no. 2 of 11.

2) Only observations were made in test no. 6 as per sheet no. 2 of 11 as per customer's request.

As per sheet 2 of 11.

NOTE: All the mentioned test on sheet 2 of 11 were tested at a frequency of 50 Hz.

PREPARED BY

As per sheet 2 of 11.

CHECKED BY

(S. B. Patel)
APPROVED BY

Note: 1. This report relates only to the particular sample received for testing in good condition at E.R.D.A.

2. This report cannot be reproduced in part under any circumstances.

3. Publication of this report requires prior permission in writing from Director , E.R.D.A.

4. Only the tests asked for by the customer have been carried out.

5. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has arised.

Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides

authenticity of test reports issued by ERDA.





(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail : erda@erda.org

Web : http://www.erda.org



SHEET: 02 of 11

REPORT NO.: RP-1516-051614

DATE

: 29.03.2016

TEST DETAILS:

SR. NO.	TEST DETAILS	TEST SPECIFICATION	
1.	Sealing test	As per cl.no.2.4.1.a of IS 2993:1998	
2.	Voltage test between terminals	As per cl.no.2.4.1.b of IS 2993:1998	
3.	Voltage test between terminals and case	As per cl.no.2.4.1.c of IS 2993:1998	
4.	Visual examination	As per cl.no.2.4.1.d of IS 2993:1998	
, 5.	Capacitance measurement As per cl.no.2.4.1.e of IS 2993:19		
6.	Tangent of loss angle	As per cl.no.2.4.1.f of IS 2993:1998	
7.	Endurance Test	As per cl.no.2.13 of IS 2993:1998	
8.	Self-Healing Test	As per cl.no.2.15 of IS 2993:1998	

PREPARED BY

CHECKED BY

1900752



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org
Web : http://www.erda.org



SHEET: 03 of 11

REPORT NO.: RP-1516-051614

DATE : 29.03.2016

Test serial no. 1 to 6 conducted on all 31 nos. capacitor (Mark no. 1 to 31)

Sr. No.	Particulars of Tests & Cl. No.	Requirement as per Specification	Obtained Value	Remarks
1.	Sealing test (Cl. No.: 2.4.1.a)	The capacitors shall be mounted in an oven at a temperature of $10^{\circ}\text{C} \pm 2^{\circ}\text{C}$ higher than the maximum permissible capacitor operating temperature , for sufficient time for all parts of the capacitor to reach this temperature. It shall be maintained at this temperature for one hour before cooling. No liquid leakage or distortion in case shall occur. Liquids are allowed to wet the surface but not to form droplets.	No liquid leakage or case distortion observed after all capacitors were heated in air circulating chamber at 95±2°C temperature for one hour, where maximum permissible capacitor operating temperature was 85°C.	Conforms
2.	Voltage test between terminals (Cl. No.: 2.4.1.b)	Capacitors shall withstand ac test voltage of 2U _N between terminals for 2 seconds, at rated frequency, as per table 2a of IS 2993:1998. During the test no flash over or permanent breakdown shall occur.	All capacitors withstood the 880 Volts ac for 2 seconds. During the test no flash over or permanent breakdown occurred.	Conforms
3.	Voltage Test between Terminals and Case (Cl. No.: 2.4.1.c)	Capacitors shall withstand 2U _N +1000 V but not less than 2000 V ac for 02 seconds, between terminals joined together & capacitor case. No routine test is required if the case is made entirely of insulation material.	All capacitors withstood the 2000 Volts ac for 2 seconds, between terminals joined together & capacitor case.	Conforms

PREPARED BY

CHECKED BY



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail : erda@erda.org

Web : http://www.erda.org





REP DAT	EPORT NO.: RP-1516-051614 SHEET: 04 of 1 ATE: 29.03.2016			: 04 of 11
Sr. No.	Particulars of Tests & Cl. No.	Requirement as per Specification	Obtained Value	Remarks
4.	Visual Examination (Cl. No.: 2.4.1.d)	The condition, workmanship, marking and finish shall be satisfactory. The marking shall be legible after rubbing the marking for 15s with a piece of cotton cloth soaked in water. The test shall be repeated with further piece of cloth, soaked in petroleum sprit.	The condition, workmanship, marking and finish are satisfactory for all capacitors. The marking is legible after rubbing the marking for 15s with a piece of cotton cloth soaked in water and petroleum sprit respectively.	Conforms
5.	Capacitance Measurement (Cl. No.: 2.4.1.e)	Capacitance shall be measured at rated voltage and frequency. It shall not deviate from the specified value. Specified value: 35 MFD ± 5%	Measured values for all capacitors are not deviated from 35.00 MFD ± 5% for all capacitors. Measured values for all capacitors are as per Table-1 on sheet 07 of 11.	Conforms
6.	Tangent of Loss Angle (Cl. No.: 2.4.1.f)	The tangent of loss angle shall be measured at rated voltage and frequency.	Measured values for all tangent of loss angles are as per Table-2 on sheet 08 of 11. Only observation were made as per customer's request.	

PREPARED BY



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382
E-mail : erda@erda.org
Web : http://www.erda.org



REP DAT	ORT NO.: RP-15 E : 29.03		SHEET	: 05 of 11
Test	serial no. 7 cond	ucted on 21 nos. capacitor (Ma	ark no. 1 to 21)	
Sr. No.	Particulars of Tests & Cl. No.	Requirement as per Specification	Obtained value	Remarks
7.	Endurance Test (Cl. No.: 2.13)	The batch of 21 nos. capacitors is kept in a hot air circulating chamber at $(t_C-15)^\circ C$ and energized according to the appropriate voltage and test cycle. The thermocouple is placed on the capacitor having the lowest tan δ value. During the first 24 h, the difference between t_c and the indication of the temperature recording instrument shall be noted and adjustments made to ensure the temperature of each capacitor case is at $t_c \pm 2^\circ C$. The test is then continued to the end of the appropriate test time.	All the capacitors were kept at 70°C in energized condition at 550V. After 24hour time measured case temperature was 76°C. Then test temperature of case for each capacitor was maintained at 85°C±2°C throughout the test. The capacitors were energized at 1.25Un (i.e 550V) for 600h continuously. During the test, no permanent breakdown, interruption or flashover occurred.	Conforms
		The capacitors are energized at 1.25Un for 600h continuously. During the test, no permanent		
		breakdown, interruption or flashover shall occur. No leak should be apparent which forms droplets within 10 min when kept at upper temperature limit in the most	Leakage was observed on one capacitor(Mark no. 1)	
		unfavorable position. At the end of the test, the capacitors shall cool down freely to the ambient temperature. The capacitance is then measured. Permitted change is 3%.	The capacitance was then measured. Measured values of capacitance for all capacitors after and before this test are as per table-3 on Sheet 09 of 11. Change in capacitance was	
	1 014	No. of failures allowed: 2 nos.	not more than 3 %.	

CHECKED BY

900755



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org Web : http://www.erda.org





REPORT NO.: RP-1516-05	1614	SHEET	: 06 of 11
DATE : 29.03.2016			
Test serial no. 8 conducted	on 10 nos. capacitor (Mark no. 22 to	31)	
Sr. Particulars of Tests No. & Cl. No.	Requirement as per Specification	Obtained value	Remarks
8. Self-healing Test (Cl. No.: 2.15)	Capacitors are subjected to 2.0U _N ac (at 880 V) for 60 seconds, between its terminals. If fewer than five self-healing breakdowns (clearings) occur during this time, the voltage shall be increased at a rate of not more than 200 V per minute until five clearings have occurred since the beginning of the test or until the voltage has reached a maximum of 3.5 U _N . The voltage shall then be decreased to 0.8 times the voltage at which the fifth clearing occurred or 0.8 times the maximum voltage and maintained for 10 s. One additional clearing in each capacitor shall be permitted during this period. The capacitors shall meet the following requirements: a) change of Capacitance is < 0.5% b) RC value is ≥ 100 s.	Obtained results are as per Table-5 on sheet 10 of 11. Measured values of capacitance for all capacitors after and before this test are as per table-4 on Sheet 10 of 11. Change in capacitance observed <0.5 %. RC value > 100s observed.	Conforms
Specceff	Zema	as graducts	
PREPARED 'BY	CHECKED BY		



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail : erda@erda.org

Web : http://www.erda.org



SHEET: 07 of 11

REPORT NO.: RP-1516-051614

DATE : 29.03.2016

Table -1 (for Routine test Sr. No. 5)

Measurement of capacitance:

MARK NO.	MEASURED CAPACITANCE (μF)	ΔC(%)	MARK NO.	MEASURED CAPACITANCE (μF)	ΔC(%)
1	35.138	0.39	17	35.224	0.64
2	35.282	0.81	18	35.225	0.64
3	35.171	0.49	19	35.216	0.62
4	35.099	0.28	20	35.093	0.27
5	35.320	0.91	21	35.258	0.74
6	35.120	0.34	22	35.218	0.62
7	35.202	0.58	23	35.195	0.56
8	35.236	0.67	24	35.228	0.65
9	35.151	0.43	25	35.292	0.83
10	35.175	0.50	26	35.231	0.66
11	35.216	0.62	27	35.175	0.50
12	35.186	0.53	28	35.270	0.77
13	35.409	1.17	29	35.169	0.48
14	35.178	0.51	30	35.099	0.28
15	35.284	0.81	31	35.140	0.40
16	35.210	0.60			

Remark: Measured values are not deviated from $35.00 \text{ MFD} \pm 5\%$ for all capacitors.

PREPARED BY





(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail : erda@erda.org Web : http://www.erda.org



SHEET: 08 of 11

REPORT NO.: RP-1516-051614

DATE : 29.03.2016

Table - 2 (for Routine test Sr. No. 6)

Measured Tangent of loss angle:

MARK NO.	Measured Tangent of loss angle	MARK NO.	Measured Tangent of loss angle
1	0.000324	17	0.000377
2	0.000398	18	0.000415
3	0.000333	19	0.000324
4	0.000436	20	0.000342
5	0.000446	21	0.000394
6	0.000442	22	0.000365
7	0.000357	23	0.000337
8	0.000337	24	0.000364
9	0.000326	25	0.000377
10	0.000339	26	0.000378
11	0.000349	27	0.000366
12	0.000394	28	0.000378
13	0.000372	29	0.000376
14	0.000360	- 30	0.000409
15	0.000377	31	0.000338
16	0.000373		<u>uu</u> s

PREPARED BY



(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382 E-mail : erda@erda.org

Web : http://www.erda.org



SHEET: 09 of 11

REPORT NO.: RP-1516-051614

DATE : 29.03.2016

Table -3 (for Type test Sr. No.7)

Measurement of capacitance before and after Endurance test was:

MARK NO.	CAPACITANCE (µF) BEFORE TEST	CAPACITANCE (µF) AFTER TEST	ΔC(%)
1	35.138	35.123	-0.04
2	35.282	35.250	-0.09
3	35.171	35.142	-0.08
4	35.099	35.079	-0.06
5	35.320	35.295	-0.07
6	35.120	35.122	0.01
7	35.202	35.172	-0.09
8	35.236	35.224	-0.03
9	35.151	35.122	-0.08
10	35.175	35.152	-0.07
11	35.216	35.205	-0.03
12	35.186	35.162	-0.07
13	35.409	35.387	-0.06
14	35.178	35.149	-0.08
15	35.284	35.260	-0.07
16	35.210	35.158	-0.15
17	35.224	35.202	-0.06
18	35.225	35.207	-0.05
19	35.216	35.146	-0.20
20	35.093	35.086	-0.02
21	35.258	35.210	-0.14

Remark: Change in capacitance observed is not more than 3 %.

PREPARED BY





(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

: +91 (0265) 2638382 Fax E-mail: erda@erda.org

Web : http://www.erda.org



SHEET: 10 of 11

REPORT NO.: RP-1516-051614

DATE : 29.03.2016

Table -4

(for Type test Sr. No.8) Measurement of capacitance before and after Self-Healing test was:

MARK NO.	CAPACITANCE (µF) BEFORE TEST	CAPACITANCE (µF) AFTER TEST	ΔC (%)
22	35.218	35.226	0.02
23	35.195	35.206	0.03
24	35.228	35.236	0.02
25	35.292	35.299	0.02
26	35.231	35.240	0.03
27	35.175	35.182	0.02
28	35.270	35.277	0.02
29	35.169	35.178	0.03
30	35.099	35.101	0.01
31	35.140	35.147	0.02

Remark: Change in capacitance observed is not more than 0.5 %.

Table - 5 (for Type test sr. no. 8) Measurement of self-healings:

MARK NO.	VOLTAGE AT WHICH ≥ 5 SELF- HEALINGS OBSERVED (Ut)	NO. OF SELF-HEALINGS OBSERVED AT 0.8 Ut	RC Value (s)
22	890 V	0	195.5
23	885 V	0	197.9
24	887 V	0	195.9
25	881 V	0	194.5
26	895 V	0	197.3
27	897 V	0	194.9
28	882 V	0	197.5
29	889 V	0	197.3
30	885 V	0	199.0
31	887 V	0	198.6

PREPARED BY

CHECKED BY

must





(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India) ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX: +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382

E-mail : erda@erda.org
Web : http://www.erda.org




PHOTOGRAPH OF TEST SAMPLE

REPORT NO.: RP-1516-051614 SHEET: 11 of 11

DATE : 29.03.2016

Test Sample (one of the sample from batch)



Rating plate



PREPARED BY

CHECKED BY

765

190